



September 7, 2023

Dear KIPP Philadelphia Preparatory Academy Community,

As a part of KIPP Philadelphia Schools effort to provide students and staff with safe and accessible drinking water, 12 water outlets at your school were tested for lead on September 1, 2023. A trained technician collected samples from water outlets and the samples were sent to an accredited Pennsylvania laboratory for analysis.

Test results showed all outlets were found to have no detectable lead in water. As such no further action is necessary to provide safe drinking water to our students and staff. If there are any further actions taken on our part, more information will immediately be sent to you.

All test results are shown below:

Sample Date	Outlet Description	Lead Result (ppb)	Action Limit
			(10 ppb)
09/01/2023	CAFETERIA	<1.0	Below
09/01/2023	CAFETERIA KITCHEN	1.4	Below
09/01/2023	GYM	<1.0	Below
09/01/2023	HALLWAY (ACROSS FROM RM 203)	<1.0	Below
09/01/2023	HALLWAY (ACROSS FROM RM 303)	<1.0	Below
09/01/2023	HALLWAY (NEXT TO RM 104)	<1.0	Below
09/01/2023	NEAR STUDENT ENTRANCE (KIPP SIGN)	<1.0	Below
09/01/2023	OUTSIDE OF BOY'S BATHROOM	<1.0	Below
09/01/2023	OUTSIDE OF BOY'S BATHROOM (ACROSS FROM MAIN OFFICE)	<1.0	Below
09/01/2023	OUTSIDE OF GIRL'S BATHROOM	<1.0	Below
09/01/2023	OUTSIDE OF GIRL'S BATHROOM (ACROSS FROM RM 223)	<1.0	Below
09/01/2023	OUTSIDE OF GIRL'S BATHROOM (ACROSS FROM RM 131)	<1.0	Below
09/01/2023	OUTSIDE OF GIRL'S BATHROOM (NEAR RAMP)	<1.0	Below

Notes:

< - not detected above detection limit

ppb - parts per billion

If you have any questions about lead in drinking water and impacts to children's health visit www.pennvestleadtestingprogram.com or you may contact me at any time. Other resources at your disposal are the Department of Health (DOH) Lead Information Line, 1-800-440-LEAD and the Department of Environmental Protection (DEP), Bureau of Safe Drinking Water (BSDW), Resource account, RA-EPWIINLEAD@pa.gov and phone number: 717-787-9633.

Sincerely,

Patrice Green
Regional Director of Operations